

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

JAVIER NUNEZ
PRESIDENT

ELVIN W. MOON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
LAUREL GILLETTE
GEORGE HOVAGUIMIAN

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

OSAMA YOUNAN, P.E.
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

JOHN WEIGHT
EXECUTIVE OFFICER

CETCO
2870 Forbs Ave
Hoffman Estates, IL 60192

Attn: Building Materials
(847) 851-1800

RESEARCH REPORT: RR 25669
(CSI 07110)

Expires: June 1, 2024

Issued Date: May 1, 2022

Code: 2020 LABC

GENERAL APPROVAL– Renewal - Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System for Wall and Slab Waterproofing.

DETAILS

1. The above product is approved for below-grade waterproofing as required by Chapter 18 of the Los Angeles Building Code. The product may be used in conjunction with Los Angeles City approved caulking materials at penetrations of the waterproofing membrane.
2. The application of the material shall be in accordance with the manufacturer's instructions. A copy of the instruction shall be available at each job site.
3. The product shall be in full contact with the wall and soil at all times.
4. The maximum allowable hydrostatic pressure of the Strataseal HR is 64.5 psi.

CETCO

Re: Strataseal HR Hot Applied Rubberized Asphalt Waterproofing System

DISCUSSION

The report is in compliance with the 2020 Los Angeles City Building Code.

The approval is based on tests.

Strataseal HR was tested with 129 psi Hydrostatic Resistance.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

EUGENE BARBEAU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Email – engineering-research@lacity.org

EB
RR25669
TLB2200059
R04/15/2022
1805.3